

Product Certification Schedule

Schedule No: 048/001/155
Licensee: TRATOS LIMITED, SCHOOL LANE, KNOWSLEY, MERSEYSIDE, L34 9HD
Factory: TRATOS LIMITED, SCHOOL LANE, KNOWSLEY, MERSEYSIDE, L34 9HD
Specification: BS 6004:2000 Incorporating Amendment Nos. 1 & 2 - Electric Cables - PVC insulated, non-armoured cables for voltages up to and including 450/750 V, for electric power, lighting and internal wiring..
Type of Cable: Table 7 - PVC insulated, PVC sheathed cable, 300/500 V, single core, flat twin and 3-core.
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: Copper Conductor Cables - 1.0sqmm - 35sqmm nominal cross-sectional areas of conductor inclusive. Single core. Sheath - Type 6. Insulation - T11.
Origin Thread: BROWN/GREY/ORANGE/YELLOW
Origin Mark: x TRATOS x

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 17/01/2013



Signed for and on behalf of the British Approvals Service for Cables

Graham R O'Leary

Date 17/12/2009



004