

Product Certification Schedule

Schedule No. 048/001/158
 Licensee: TRATOS LIMITED, SCHOOL LANE, KNOWSLEY, MERSEYSIDE, L34 9HD
 Factory: TRATOS LIMITED, SCHOOL LANE, KNOWSLEY, MERSEYSIDE, L34 9HD
 Specification BS 6004:2000 Incorporating Amendment Nos. 1 & 2 - Electric Cables - PVC insulated, non-armoured cables for voltages up to and including 450/750 V, for electric power, lighting and internal wiring.
 Type of Cable Table 4b - PVC insulated, non-sheathed general purpose cable, 450/750 V, single-core (flexible copper conductor).
 HAR Document HD 21.3 S3
 HAR Specification H07V-K
 Range of Approval Flexible Conductor Cables - Plain annealed copper conductors. 1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Insulation - T11.
 Origin Thread BROWN/GREY/ORANGE/YELLOW
 Origin Mark x TRATOS x

PERMISSIBLE MARKS



BASEC ◁ HAR ▷

BLACK - 1cm
 RED - 1cm
 YELLOW - 3cm
 THREAD

Note: The black - red - yellow thread has been registered in this country as an identification thread in the BSI 'Register of colours of manufacturers' threads for electric cables and cords' for Verband Deutscher Elektrotechniker (VDE) e.V., Frankfurt, Germany. VDE has authorized BASEC to use this thread.

Please refer the BASEC Product Certification Requirements

Expiry Date: 17/01/2013



Signed for and on behalf of the British Approvals Service for Cables

Graham R. Olsen

Date 17/12/2009

