

Product Certification Schedule

Schedule No. 048/001/165
 Licensee: TRATOS LIMITED, SCHOOL LANE, KNOWSLEY, MERSEYSIDE, L34 9HD
 Factory: TRATOS LIMITED, SCHOOL LANE, KNOWSLEY, MERSEYSIDE, L34 9HD
 Specification BS 6004:2000 Incorporating Amendment Nos. 1 & 2 - Electric Cables - PVC insulated, non-armoured cables for voltages up to and including 450/750V, for electric power, lighting and internal wiring.
 Type of Cable Table 4a - PVC insulated, non-sheathed general purpose cable, 450/750 V single-core (rigid copper conductor).
 HAR Document HD 21.3 S3
 HAR Specification Solid conductor: H07V-U; Stranded conductor: H07V-R
 Range of Approval 1.5sqmm to 120sqmm nominal cross-sectional area of conductors inclusive. Stranded conductors. Single-core. Insulation - T11.
 Origin Thread BROWN/GREY/ORANGE/YELLOW
 Origin Mark x TRATOS x

PERMISSIBLE MARKS



BASEC ◁ HAR ▷

BLACK - 1cm
 RED - 1cm
 YELLOW - 3cm
 THREAD

Note: The black - red - yellow thread has been registered in this country as an identification thread in the BSI "Register of colours of manufacturers' threads for electric cables and cords" for Verband Deutscher Elektrotechniker (VDE) e.V., Frankfurt, Germany. VDE has authorized BASEC to use this thread.

Please refer the BASEC Product Certification Requirements

Expiry Date: 17/01/2013



Signed for and on behalf of the British Approvals Service for Cables

Graham R O'Shea

Date 17/12/2009

