

Loss Prevention Certification Board



This is to certify

TRATOS CAVI SpA

52036 Pieve S. Stefano (AR), Via Stadio 2, Arezzo, Italy

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

Firesafe Enhanced Fire Resistant Cables

(Refer to attached Appendix for details)

has complied with the requirements of the following:

BS 7629-1: 1997 (Incorporating Amendments Nos. 1 & 2) – 300/500V fire resistant electric cables having low emission of smoke and corrosive gases when affected by fire – Multicore cables.

Enhanced fire resistant cables as described in Clause 26.2 of BS 5839-1: 2002 – Fire detection and alarm systems for buildings. Code of practice for system design, installation, commissioning and maintenance.

and achieved:

Class PH120 when tested in accordance with BS EN 50200: 2000 – Method of test for resistance to fire of unprotected small cables for use in emergency circuits.

Certificate No. 222b


Issue No. 01

Date of Issue 06 July 2006

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.